THE UNIVERSITY *of* EDINBURGH

Edinburgh Research Explorer

Enhanced multi-terminal HVDC grid management for reliable AC network integration

Citation for published version:

Macpherson, E, Akhter, F & Harrison, G 2014, Enhanced multi-terminal HVDC grid management for reliable AC network integration. in *7th IET International Conference on Power Electronics, Machines and Drives*. IET, Manchester. <https://doi.org/10.1049/cp.2014.0499>

Digital Object Identifier (DOI):

[10.1049/cp.2014.0499](https://doi.org/10.1049/cp.2014.0499)

Link:

[Link to publication record in Edinburgh Research Explorer](#)

Document Version:

Peer reviewed version

Published In:

7th IET International Conference on Power Electronics, Machines and Drives

Publisher Rights Statement:

This paper is a postprint of a paper submitted to and accepted for publication in 7th IET International Conference on Power Electronics, Machines and Drives (PEMD 2014) and is subject to Institution of Engineering and Technology Copyright. The copy of record is available at IET Digital Library

General rights

Copyright for the publications made accessible via the Edinburgh Research Explorer is retained by the author(s) and / or other copyright owners and it is a condition of accessing these publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

The University of Edinburgh has made every reasonable effort to ensure that Edinburgh Research Explorer content complies with UK legislation. If you believe that the public display of this file breaches copyright please contact openaccess@ed.ac.uk providing details, and we will remove access to the work immediately and investigate your claim.

Enhanced multi-terminal HVDC grid management for reliable AC network integration

F. Akhter[†], D.E. Macpherson*, G.P. Harrison**

**Institute for Energy System, School of Engineering
University of Edinburgh, Kings Building, Edinburgh EH9 3JL, UK
[†] F.Akhter@ed.ac.uk*

Keywords: Multi-Terminal High Voltage Direct Current (MTDC) grid, Voltage Source Converter (VSC), power flow control, droop control, secondary control.

Abstract

This paper presents a secondary control for MTDC systems to update the DC voltage and converter power references of the VSC stations operating under droop control, in order to eliminate the large power deviation from their desired reference power. The rated values of the VSC station used as reference does not take into account the power losses in the converter, DC line and the voltage drops in the DC transmission lines. This creates a constant difference between rated DC voltage reference and actual DC voltage value of the VSC station. This difference is multiplied by the droop gain of the VSC station, hence causing power deviations in the MTDC grid system. In this paper a secondary control is implemented for a four-terminal HVDC system modelled in EMTDC/PSCAD, to demonstrate the reduction in power deviation by the proposed secondary control.

1 Introduction

Offshore wind energy is seen as the most promising source of electricity generation for achieving the European renewable energy targets. A number of wind farms are under installation in the North Sea, and more are planned, to collect the huge potential of wind energy at significant distances from land. This will be extended to include the interconnection between the countries to form a MTDC grid [1].

The Voltage Source Converter (VSC) technology's capabilities of multi-directional power flow and control flexibility are fundamental to a MTDC grid system. With the systematic control of the VSCs and MTDC grid system, the integration of wind farms and interconnections between countries can be made more reliable to support the AC network. The VSC-based MTDC grid system is connected to shore by a common DC link. The active power flow through all the terminals need to be balanced to keep the DC link voltage constant, similar to the constant system frequency requirement of an AC system, for the stable operation of VSC stations. A combination of primary control strategies proposed for the DC link voltage control and power flow dispatch of the MTDC grid system including Master-Slave, Voltage Margin and Voltage Droop control are suggested in [2]–[5].

The main drawback of the Master-Slave control strategy with the Voltage Margin method is that only one VSC station controls the DC link voltage of the MTDC grid system. An outage in the DC link voltage controlling VSC station leads to failure of the whole MTDC grid system. In the case of the Voltage Droop control more than one VSC station share responsibility for the DC link voltage control, therefore, outage of any single VSC station cannot cause failure of the complete MTDC grid system. Hence, the Voltage Droop control is regarded as most suitable, because of the flexible control operation of the MTDC grid system, similar to the frequency droop control of an AC system.

Although, various advantages of the DC Voltage Droop control implementation in an MTDC grid system have been explored in the literature, little has been discussed on the issue of the power deviation from the desired reference power of the VSC station operating under the Droop Control, due to the difference in the DC voltage of the VSC stations. In [6], the impact of the DC line voltage drop on the power flow under Voltage Droop control is discussed in detail and an analytical expression is proposed to deal with this issue, but the references cannot be updated instantaneously.

Power balancing and maintaining the required power flows from the MTDC grid system is fundamental to its reliable integration with the AC network. Therefore, a secondary control of the MTDC grid system as proposed in [7], analogous to that in an AC grid system, needs to be implemented to compensate for this power deviation and instantaneously update the power and voltage references of the primary control of the VSC stations, in order to maintain the scheduled power flow dispatch from the MTDC grid system.

In this paper, a secondary control is proposed for the instantaneous update of the DC voltage reference to avoid the power deviation caused by the difference in DC voltage of the VSC stations due to the voltage drop in the DC lines. A comparison of two four-terminal HVDC grid systems modelled in EMTDC/PSCAD is presented, one without the proposed secondary control and another with the proposed secondary control. The results show that secondary control can update instantaneously the DC voltage references and hence the power deviations are reduced eliminated from the MTDC grid system.

2 Control Structure of MTDC grid

The MTDC grid control is reduced to the control of a single VSC station (as a fundamental unit of the MTDC grid system); similarly, the control of the AC grid is represented by the control of a synchronous generator. The similarities between the MTDC grid control structure and AC grid control structure is shown in **Error! Reference source not found..** The primary control of the MTDC grid system comprises an inner and an outer controller, analogous to the exciter and governor control of the AC grid system. The secondary control is introduced to supply updated references for primary control to avoid the power deviation and obtain scheduled power flow dispatch from the MTDC grid system.

Figure 1: AC and MTDC grid control structure comparison

2.1 Primary Control

The primary control maintains the basic VSC station operation by the inner controller, and ensures the co-ordinated balance operation of the MTDC grid system as a whole through the outer controller. The detailed primary control structure of the MTDC grid system is shown in Figure 3.

The inner controller uses synchronously rotating dq reference control, explained in [8] [9], which decouples active and reactive power control to provide independent active and reactive power control at each VSC station, similar to how the governor and the exciter provide independent control in the AC grid system.

The outer controller can be operated under various modes of operation according to the requirements of the MTDC grid system. The operation modes include: constant active power or constant DC link voltage; constant reactive power or constant AC voltage. The control mode that most closely resembles the frequency droop control of the AC grid system is DC voltage droop control [10] as shown in **Error! Reference source not found..**

The implementation of the DC droop controller is given by:

$$P_c = P_{c ref} + R (U_{dc ref} - U_{dc}) \quad (1)$$

Figure 2: Primary droop control comparison of AC and MTDC grid

where, P_c is actual power at the Point of Common Coupling (PCC) of the VSC station, $P_{c ref}$ is desired reference power, R is the droop gain of the DC voltage controller, U_{dc} is the actual DC link voltage at the VSC station and $U_{dc ref}$ is the rated DC link voltage for the VSC station.

However, when rated DC link voltage values are used for $U_{dc ref}$, this does not take into account the voltage drops in the transmission line. The difference, when multiplied by the droop gain of the DC voltage controller, produces a large deviation in the actual power P_c of the converter station. To avoid this power deviation a power flow analysis can be performed to produce an appropriate DC voltage reference by keeping one VSC station as voltage regulator as suggested in [10], whereas, with the proposed secondary control described in this paper, it can be achieved instantaneously without the need for power flow analysis.

Figure 3: Detailed primary control structure of the MTDC grid system

VSC stations	VSC1	VSC2	VSC3	VSC4
$P_{C\ ref}$ (MW)	-90	10	30	50
$U_{dc\ ref}$ (kV)	–	50	50	50
R_{DC} (MW/kV)	–	40	40	40

4 Simulation results

4.1 MTDC system under droop with no secondary control

The first simulation is performed with set reference from Table 1; here the DC voltage reference for the three VSC stations under DC Droop control is the rated DC link voltage. It can be observed from Figures 6 and 7 that power deviations are proportional to the difference between the reference DC voltage (i.e. $U_{dc\ ref}=50\text{kV}$) and the actual DC voltage (U_{dc}). Table 2 shows deviations in power by the difference of the in the DC link.

Table 2: Power deviations and DC voltage difference

VSC Station	VSC1	VSC2	VSC3	VSC4
P_c (MW)	-90	8.76	50.126	31.34
U_{dc} (kV)	-	49.625	50.002	49.973
ΔP (MW)	0.0	-1.24	0.126	1.34
ΔU (kV)	-	-0.375	0.002	-0.027

Figure 7 DC link voltages without secondary control

4.2 MTDC system under droop with secondary control

In the second simulation, the secondary control is applied and the DC link voltage references for the three VSC stations (VSC2, VSC3, VSC4) are updated according to the voltage drops in the DC transmission line. Figures 8 and 9 show that power deviation of the VSC station is reduced and precise power flow can be obtained from the MTDC grid system without need of references being updated through the DC power flow analysis.

Figure 6: Actual and reference power without secondary control

Figure 8: Actual and reference power with secondary control

Figure 9: DC link voltages with secondary control

5 Conclusion

In this paper a secondary control has been proposed to update the DC voltage and converter power references of the VSC stations operating under droop control, in order to reduce the large power deviation from their desired reference power. It is observed that DC voltage rated values of the VSC station used as reference causes power deviation in the MTDC grid system. The proposed secondary control can provide updated references for primary control to avoid the power deviation and obtain scheduled power flow dispatch from the MTDC grid system.

Acknowledgements

The author would like to acknowledge the affiliation and funding resources for this research from Sukkur Institute of Business Administration, Sukkur, Pakistan.

References

- [1] E. Summary, "Eueopean Offshore Suppergrid Proposal," 2010.
- [2] J. Zhu and C. Booth, "Future Multi-Terminal HVDC Transmission Systems using Voltage Source Converters," pp. 1–6, 2010.
- [3] R. T. Pinto, "Comparison of Direct Voltage Control Methods of Multi-Terminal DC (MTDC) Networks through Modular Dynamic Models," pp. 1–10.
- [4] L. Xu and L. Yao, "DC voltage control and power dispatch of a multi-terminal HVDC system for integrating large offshore wind farms," *IET Renew. Power Gener.*, vol. 5, no. 3, p. 223, 2011.
- [5] R. Silva, R. Teodorescu, S. Member, and P. Rodriguez, "Power Delivery in Multiterminal VSC-HVDC Transmission System for Offshore Wind Power Applications," pp. 1–8.
- [6] T. M. Haileselassie and K. Uhlen, "Impact of DC Line Voltage Drops on Power Flow of MTDC Using Droop Control," *IEEE Trans. Power Syst.*, vol. 27, no. 3, pp. 1441–1449, Aug. 2012.
- [7] J. Beerten and D. Van Hertem, "PRIMARY AND SECONDARY POWER CONTROL OF MULTITERMINAL HVADC GRID."
- [8] T. Nakajima, S. Irokawa, and T. Corporation, "A Control System for HVDC Transmission by Voltage Sourced Converters," pp. 1113–1119, 1999.
- [9] C. Bajracharya, M. Molinas, M. Ieee, J. A. Suul, T. M. Undeland, and F. Ieee, "Understanding of tuning techniques of converter controllers for VSC-HVDC," 2008.
- [10] T. M. Haileselassie and K. Uhlen, "Precise control of power flow in multiterminal VSC-HVDCs using DC voltage droop control," *2012 IEEE Power Energy Soc. Gen. Meet.*, pp. 1–9, Jul. 2012.