THE UNIVERSITY *of* EDINBURGH

Edinburgh Research Explorer

Measured and simulated thermal behaviour in rammed earth houses in a hot-arid climate

Citation for published version:

Beckett, C, Cardell-Oliver, R, Ciancio, D & Huebner, C 2017, 'Measured and simulated thermal behaviour in rammed earth houses in a hot-arid climate: Part B: Comfort', *Journal of Building Engineering*, vol. 13, pp. 146-158. <https://doi.org/10.1016/j.jobbe.2017.07.013>

Digital Object Identifier (DOI):

[10.1016/j.jobbe.2017.07.013](https://doi.org/10.1016/j.jobbe.2017.07.013)

Link:

[Link to publication record in Edinburgh Research Explorer](#)

Document Version:

Peer reviewed version

Published In:

Journal of Building Engineering

General rights

Copyright for the publications made accessible via the Edinburgh Research Explorer is retained by the author(s) and / or other copyright owners and it is a condition of accessing these publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

The University of Edinburgh has made every reasonable effort to ensure that Edinburgh Research Explorer content complies with UK legislation. If you believe that the public display of this file breaches copyright please contact openaccess@ed.ac.uk providing details, and we will remove access to the work immediately and investigate your claim.

Measured and simulated thermal behaviour in rammed earth houses in a hot-arid climate. Part B: Comfort

C.T.S. Beckett^a, R. Cardell-Oliver^{b,*}, D. Ciancio^a, C. Huebner^c

^a*School of Civil, Environmental and Mining Engineering, The University of Western Australia*

^b*School of Computer Science & Software Engineering, The University of Western Australia*

^c*Institute for Industrial Data Processing and Communication, University of Applied Sciences
Mannheim*

Abstract

Heating and cooling of residential buildings consumes around ten percent of the world's energy. One approach for reducing these costs is solar passive design using building materials with high thermal mass such as Rammed Earth (RE). Several studies have examined the performance of small RE structures or individual rooms within RE dwellings and have demonstrated the material's capacity to passively provide comfortable internal conditions. However, there is a lack of scientific evidence about the performance of full RE houses in real-world settings spanning several seasons. This research investigated the thermal performance of RE structures prior to occupancy and over the course of an occupied year. Two custom-designed houses were built in the hot-arid city of Kalgoorlie-Boulder, Western Australia: one with traditional solid RE walls and the other with walls with an insulating polystyrene core (iRE). Otherwise the houses were identical in orientation and design.

This study is presented in two Parts. Part A examined the houses' performance without occupants: This Part examines their occupied behaviour in terms of the occupants' thermal comfort. Comfort was examined using qualitative and quantitative data from sensor measurements as well as occupant surveys and

simulated results using state-of-the-art assessment software *BERS Pro*. Comfort scores for measured and simulated data were determined using rules built into *BERS Pro*'s engine *Chenath* and a modified version of the ANSI/ASHRAE Standard 55-2010 SET* method.

Real-world thermal comfort of both houses outperformed their simulated behaviours: occupants reported comfortable conditions throughout Summer (outdoor maxima 45°C) and Winter (minima 1°C) with no artificial cooling and with minimal heating. The *Chenath* and SET* methods agreed with comfort performance in Summer but scored Winter performance poorly. Similarly, simulations predicted poor performance in Winter. Consequently, predicted energy demands due to heating were likely far higher than those needed in reality. This paper therefore argues from measured evidence of RE and iRE houses for the suitability of RE as a sustainable building material able to curb domestic energy demands. Collected data has been made publicly available for future analyses.

Keywords: rammed earth, thermal comfort, environmental monitoring, rural housing

*Corresponding author

Email address: rachel.cardell-oliver@uwa.edu.au (R. Cardell-Oliver)

Preprint submitted to Elsevier

June 16, 2017

1	Contents	
2	1 Introduction	4
3	2 Data Management	6
4	2.1 Virtual Sensors	6
5	2.2 Simulations	7
6	3 Thermal performance metrics	8
7	3.1 Occupant surveys	8
8	3.2 Thermal comfort	9
9	3.2.1 <i>Chenath</i> assessment	10
10	3.2.2 SET* assessment	11
11	4 Results and Discussion	13
12	4.1 Surveys	13
13	4.2 Outdoor temperatures	14
14	4.3 Indoor temperatures	14
15	4.3.1 Summer	16
16	4.3.2 Winter	16
17	4.4 Thermal comfort	19
18	4.4.1 Summer	22
19	4.4.2 Winter	27
20	4.5 Comfort model consequences on energy efficiency	36
21	5 Conclusions	36

22 1. Introduction

23 Rammed earth (RE) is a high thermal mass construction method relied upon
24 for millennia to passively provide comfortable living conditions [13]. In RE,
25 soil is compacted into formwork in layers to produce thick, freestanding high
26 density ($\sim 2000\text{kg/m}^3$) walls. Depending on its quality and grading, soil can be
27 claimed directly from the site, making RE an ideal choice for construction where
28 transportation costs can be prohibitive, as is the case in rural Australia and
29 other communities around the world [5]. However, the global RE industry is at
30 a critical juncture. On the one hand, it has the potential to offer sustainable,
31 low-embodied energy construction and to curb domestic energy demands. On
32 the other, its use is threatened by new and/or inappropriate regulations on its
33 thermal properties and design. One such example are those imposed by the
34 Australian Nationwide House Energy Rating Scheme (NatHERS), which often
35 rates RE thermal performance poorly despite vernacular evidence to the contrary.
36 Recent research has identified shortfalls in these regulations [6–8]. However, more
37 evidence is needed to adapt them to better reflect actual RE thermal performance.
38 As a leader in RE construction (e.g. Ciancio and Beckett [4]), adaptations to
39 Australian regulations will encourage similar changes around the world.

40 In this series, we contrast the unoccupied and occupied thermal behaviour of
41 two houses, one built with traditional solid RE walls (RE) and the other with
42 walls with an insulating polystyrene core (iRE). The houses are hereafter referred
43 to as the “monolithic” and “insulated” houses respectively. The houses were built
44 in Kalgoorlie-Boulder, Western Australia (WA) and designed to optimise passive
45 solar behaviour, making extensive use of thermal mass, optimised ventilation and
46 orientation. Performance prior to occupancy was discussed in Part A of this se-

47 ries. That paper described the houses' construction and instrumentation, our
48 experimental approach and the strategies used for data collection and manage-
49 ment. Unoccupied performance was quantified in terms of thermal stability (the
50 ability to resist large changes in diurnal temperature) and thermal lag (the ability
51 to offset peak temperatures): features important to controlling thermal comfort.
52 Performance in all rooms was measured using a suite of sensors and simulated
53 using NatHERS software *BERS Pro* (v4.3). We showed that thermal stability and
54 lag were similar in both houses despite differences in their construction: the more
55 costly iRE did not provide a notable benefit in the WA climate. Notably, *BERS*
56 *Pro* simulated thermal stability and lag did not match measured values: stability
57 scores were significantly poorer and lags significantly longer in rooms with lower
58 and higher thermal mass envelopes respectively.

59 Part B of this series expands on Part A's findings to examine the houses' oc-
60 cupied performance over twelve months. Again, performance was evaluated using
61 measured data and simulated data from *BERS Pro*. Comfort scores based on the
62 *Chenath* assessment method (used within *BERS Pro*) applied to measured data
63 were compared to occupant feedback, obtained through regular surveys, to exam-
64 ine *Chenath*'s ability to match reported data and identify causes for discrepan-
65 cies. *Chenath* scores were also contrasted against those from the ANSI/ASHRAE
66 Standard 55-2010 SET* method to examine strengths and weaknesses in the as-
67 sessment criteria [1]. Data presented in both Parts of this study have been made
68 publicly available and can be downloaded from [http://datascience.ecm.uwa.](http://datascience.ecm.uwa.edu.au:55555/)
69 [edu.au:55555/](http://datascience.ecm.uwa.edu.au:55555/). A timeline describing the unoccupied and occupied analyses
70 covered during this series is given in Table 1.

71 (Insert Table 1 somewhere near here)

Table 1: Analysis timeline. MMT: Mean Monthly Temperature ($^{\circ}\text{C}$)

Year	2014				2015												2016			
Month	S	O	N	D	J	F	M	A	M	J	J	A	S	O	N	D	J	F	M	
Max MMT	24.6	29.3	30.0	32.7	34.9	36.8	29.1	22.4	20.0	19.5	17.3	18.5	23.5	30.9	31.0	32.9	32.8	31.6	27.8	
Min MMT	10.4	14.5	15.5	16.8	18.8	20.8	16.7	12.3	8.0	7.2	6.2	7.7	8.2	15.7	16.6	16.8	19.0	18.0	17.1	
Period	Unoccupied												Occupied							
Season	Unoccupied												Winter				Summer			
Dates	01/09/14-30/11/14												14/06/15-23/09/15				21/11/15-02/03/16			

2. Data Management

This study’s experimental programme was explained in detail in Part A of this series. Here, we describe the techniques used to adapt the installed instrumentation to accommodate occupants and the simulation methodology.

2.1. Virtual Sensors

The aim of this research is to investigate the thermal behaviour of hybrid RE and iRE houses under real-world conditions. Head-level room temperatures and humidities are key data for the assessment. However, it was not feasible to have sensors hanging at head-level while the houses were occupied. To address this problem, we developed a machine learning algorithm that learned models for accurate, long-range estimation of sensor readings [2]. At any time such “virtual sensors” estimated their readings using those from the permanent sensors mounted in the ceilings and walls. Data gathered during the unoccupied period, discussed in the first Part of this series, was used to train virtual sensors for head level temperature and humidity. Although a simple linear regression appeared to give reasonably correlated results, its fit to extreme temperatures, most notably daily maxima, was poor. For testing periods of 7 to 14 days, in 90% of the cases the error for linear regression models was within 1°C . However, as the testing period increased, the estimation accuracy decreased. On the other hand, virtual sensing was extremely accurate and stable for long periods: for up to 95% of the

92 sensor readings it achieved estimation errors within 0.5°C. “Best”, “high” and
93 “low” virtual sensor values were computed for both houses, corresponding to the
94 median, upper and lower quartiles of the prediction model. These virtual sensor
95 observations were used for thermal comfort analyses during the occupied period.

96 2.2. Simulations

97 A common grievance of occupants of Australian low-energy dwellings is that
98 NatHERS energy assessments fail to accurately capture their use of the structure
99 and so its efficiency [8]. Commentators on the accreditation process claim that
100 the disparity is due to shortfalls in the *Chenath* engine’s comfort-rating criteria.
101 Daniel et al. [6, 7, 9], Miller et al. [14] showed that the *Chenath* engine is able
102 to capture the thermal behaviour of unoccupied high thermal mass structures.
103 However, it is less able to model occupant behaviour or comfort interpretation in
104 houses designed to function passively [8].

105 In this study, house performance was simulated using *BERS Pro* v4.3 (incor-
106 porating *Chenath* v3.13, released September 2015) to compare predicted unoc-
107 cupied and occupied performance to measured data and to identify disparities
108 in any sources of discomfort. Simulations were based on 30-year average annual
109 temperature data (as required by the rating system) and provided a simulated
110 year’s worth of data for each condition (i.e. unoccupied or occupied). Wall
111 material thermal properties used in *BERS Pro* are given in Table 2.

112 (Insert Table 2 somewhere near here)

113 For unoccupied performance, simulations assumed external doors and win-
114 dows remained shut and no artificial heating or cooling (including cooking, bathing
115 etc.) was permitted. Occupied simulations assumed normal occupant activity
116 (cooking, bathing, sleeping etc.) and the opportunity to employ artificial heat-

Table 2: Material and component thermal properties used in *BERS Pro* simulations

Material/component	Density (dry) (kg/m ³)	Resistance (m ² K/W per metre)	Capacitance (kJ/m ³ K)	R-value (m ² K/W)
Rammed earth (RE)	2000	0.80	1940.0	-
Extruded polystyrene (EP)	32	35.72	340	-
Concrete	2400	0.69	2112.0	-
Steel	N/A	0.02	3900.0	-
Timber (softwood)	N/A	10.00	1057.5	-
External surface	-	-	-	0.04
Internal surface	-	-	-	0.12
Total RE wall	300mm RE			0.40
Total iRE panel	125mm RE, 50mm EP, 125mm RE			2.14

ing and cooling. The *Chenath* engine simulates cooling hierarchically. First, the effect of opening windows in that room was calculated. If that was not sufficient, occupants were assumed to activate forced air movement (e.g. from ceiling fans). Finally, if neither approach sufficiently reduced perceived temperatures, active cooling was applied in the model. Unlike cooling, no hierarchy existed for heating; if temperatures dropped below the heating threshold, artificial heating was applied [12].

3. Thermal performance metrics

3.1. Occupant surveys

The monolithic house was occupied by a family of five: two adults and three children under the age of ten. The insulated house was occupied by two adults. Both were Aboriginal families who volunteered to take part in the study and who had had no prior contact with the research team. Either family was free to withdraw at any point with no repercussions (i.e. they would not be asked to leave the houses).

132 Both families resided in the houses for the duration of the study, excepting
133 short absences for holidays in Winter. The occupants were surveyed monthly and
134 asked:

- 135 • how they would rank the thermal comfort during the day (very poor/poor/normal/excellent);
- 136 • how they would rank the thermal comfort during the night (as above);
- 137 • whether they had used the ceiling fans or heaters (and, if so, when);
- 138 • whether they had experienced any day or set of days that were too hot or
139 cold (and, if so, when);
- 140 • how many people had occupied the house (normal tenants/more or fewer),
141 with details;
- 142 • whether they were happy to continue with the study.

143 Occupants were surveyed by a local liaison officer, known in the community, to
144 reduce potential bias in their responses. Responses were obtained for the majority
145 of the surveyed months for both houses (some absences in winter). Occupants
146 were not contacted directly by the research team, except if access was needed to
147 repair equipment.

148 3.2. Thermal comfort

149 Thermal comfort was assessed by ‘scoring’ each house according to the per-
150 centage of time that hourly temperature was within comfortable thresholds. Com-
151 fort thresholds were calculated using two methods: the comfort rules used within
152 *BERS Pro* (the *Chenath* engine) as part of the NatHERS rating system; and
153 the ANSI/ASHRAE Standard 55-2010 SET* method. Scores from both methods

were compared to qualitative feedback from the occupants. Hourly contributions to Time Outside Comfort, TOC, were also examined, calculated as the percentage time that a given hour fell outside the comfort boundaries. TOC values were used to identify times in the day most responsible for poor comfort performance for both methods.

3.2.1. *Chenath assessment*

The *Chenath* engine specifies different minimum and maximum permissible temperatures for every hour of the day and rates that hour as either too hot, too cold or within tolerance. The cooling threshold (i.e. the upper comfort limit per hour), T_{upper} , varies by activity but not by room use and is defined as

$$T_{upper} = T_n + 2.5 + \Delta T \quad (1)$$

where T_n is the “trigger temperature” based on the psychrometric chart and ΔT is an offset accounting for air movement and humidity [3, 11]. T_n changes per location: in Kalgoorlie-Boulder, $T_n = 26^\circ\text{C}$. T_n also varies depending on activity: if during a sleeping period, defined as 00:00–07:00, T_n is reduced by 1.5°C [15]. ΔT is found via

$$\Delta T = [1.6 + 6(v - 0.2) - 1.6(v - 0.2)^2] + (2.67 - 0.053r) \quad (2)$$

where v is the indoor air speed (which must be between 0.2 and 2m/s) and r is relative humidity in %. The relative humidity reduces or increases acceptable temperatures for $r > 50\%$ or $r < 50\%$ respectively. A further modification is applied depending on the comfort condition of the previous hour: T_{upper} is reduced by 2°C if the previous hour exceeded its calculated T_{upper} [15]. This modifica-

Table 3: Hourly *Chenath* heating and cooling temperature thresholds. *Reduced by 2°C if previous hour was outside comfort limits

Threshold	Rooms	Times	Temperature limits (°C)
Cooling	All rooms	00:00–07:00	$T_{upper} - 1.5^*$
		07:00–00:00	T_{upper}^*
Heating	Living rooms	00:00–07:00	N/A
		07:00–00:00	20
	Bedrooms	01:00–07:00	15
		07:00–08:00	18
		16:00–00:00	18

tion forces *Chenath* to apply more rigorous cooling (if possible) to rapidly return conditions to within comfort levels.

The heating threshold (i.e. the lower comfort limit) varies by room use and activity. In living rooms, heating is required if temperature falls below $T_{lower} = 20^\circ\text{C}$ from 07:00–00:00. Comfort outside of those hours is not considered as the rooms are assumed to be vacant. In bedrooms, heating is required if temperature falls below $T_{lower} = 15^\circ\text{C}$ from 01:00–07:00 or $T_{lower} = 18^\circ\text{C}$ from 08:00–09:00 and 16:00–00:00. Otherwise, bedrooms are assumed to be empty. Unlike cooling, no penalty is applied to T_{lower} if the previous hour fell below its heating threshold. Hourly *Chenath* heating and cooling thresholds are summarised in Table 3.

(Insert Table 3 somewhere near here)

3.2.2. *SET** assessment

The *SET** method is a simpler alternative to the *Chenath* comfort rules which can easily be applied to any room of a structure. As such, its use can provide insight into what benefits the more complex *Chenath* method provides. *SET** uses a thermo-physiological simulation of the human body to define a range of comfortable temperatures according to mean monthly outdoor temperature (MMOT).

191 The input temperature, T_{SET^*} , is defined as

$$T_{SET^*} = T_i - \Delta T \quad (3)$$

192 where T_i is the indoor dry bulb temperature and ΔT is as per Eqn 2. T_{SET^*} is
193 deemed uncomfortable if it falls outside of the comfort limits for its corresponding
194 MMOT. de Dear and Brager [10] suggested an improvement to MMOT, being
195 the “thermal expectation”, T_{RM} , which includes effects of the preceding week of
196 temperatures on perceived comfort:

$$T_{RM} = 0.34T_1 + 0.23T_2 + 0.16T_3 + 0.11T_4 + 0.08T_5 + 0.05T_6 + 0.03T_7 \quad (4)$$

197 where, for a given day of observation, T_j (for $j = 1$ to 7) is the mean temperature
198 (i.e. the average of the day’s maxima and minima) for the j th preceding day.
199 For *BERS Pro* simulations, T_{RM} was calculated for the first day of each month
200 using 30-year average daily temperature data for Kalgoorlie-Boulder (BoM). This
201 value was used in place of MMOT with the ANSI/ASHRAE Standard 55-2010
202 acceptable operative temperature range chart. Measured outdoor dry bulb tem-
203 peratures from April 2015 to April 2016 were used to calculate T_{RM} for the
204 measured data set. Resulting monthly 80% acceptable minimum and maximum
205 temperatures for both data types are given in Table 4: 80% limits were used
206 rather than the tighter 90% limits to provide as broad a range of potential com-
207 fort as possible. Unlike *Chenath*, SET* limits are not affected by room type.
208 However, ANSI/ASHRAE Standard 55-2010 assumes standard daytime occupant
209 activities: T_{SET^*} is not designed to apply to nighttime comfort.

210 (Insert Table 4 somewhere near here)

Table 4: SET* monthly 80% acceptance cooling and heating thresholds for measured data (2015–2016 hourly temperatures) and *BERS Pro* simulated performance (30-year mean hourly temperatures)

Data	Threshold	January	February	March	April	May	June
Measured	Cooling (°C)	29.9	29.0	30.5	27.6	26.3	25.1
	Heating (°C)	22.9	22.0	23.5	20.6	19.3	18.1
		July	August	September	October	November	December
	Cooling (°C)	24.8	25.8	26.2	27.8	29.2	28.8
	Heating (°C)	17.8	18.9	19.3	20.9	22.2	21.8
		January	February	March	April	May	June
Simulated	Cooling (°C)	29.9	29.8	28.6	27.2	25.7	26.0
	Heating (°C)	22.9	22.8	21.7	20.2	18.7	19.0
		July	August	September	October	November	December
	Cooling (°C)	25.0	26.0	25.8	26.5	26.2	28.5
	Heating (°C)	18.0	19.0	18.8	19.5	19.3	21.5

211 4. Results and Discussion

212 This section assesses the thermal performance of the Kalgoorlie-Boulder rammed-
213 earth houses during Summer and Winter. The following questions were ad-
214 dressed:

- 215 1. How differently did the houses perform?
- 216 2. Did the residents perceive the houses to be thermally comfortable or not?
- 217 3. For how much of the time and when were the houses thermally comfortable
218 according to either simulations or measured data?
- 219 4. What were the sources of differences between the comfort scores and occu-
220 pant feedback?

221 4.1. Surveys

222 Survey results showed that both houses were comfortable *throughout Summer*
223 *and Winter*. In Summer, occupants did not use any artificial cooling (e.g. mobile

224 air conditioning) but did make use of ceiling fans. Artificial heating was used in
225 both houses in Winter: although fixed heating units were not installed, occupants
226 were free to use mobile heaters. Both houses were occupied for the entirety of
227 Summer but were reported vacant for short intervals during Winter; these periods
228 were not included in comfort analyses. Although not part of the survey, occupants
229 reported a reduction in their annual energy bills compared to previous homes and
230 excellent acoustic insulation owing to the houses' thick walls.

231 4.2. Outdoor temperatures

232 Outdoor hourly temperatures during Summer and Winter are compared in
233 Figure 1. An unpaired Welch Two sample t-test was used to assess differ-
234 ences between measured and simulated climate data; all seasons were signif-
235 icantly different between measured and simulated values (unpaired p values:
236 Summer= $3.995e - 17$; Winter= $5.712e - 04$). Simulated outdoor median, lower
237 and upper quartile temperatures were *cooler* than measured values for all sea-
238 sons. Temperature ranges were similar for Winter but smaller for Summer. Con-
239 sequences of these differences on thermal comfort are discussed in the following
240 sections.

241 (Insert Figure 1 somewhere near here)

242 4.3. Indoor temperatures

243 Hourly temperatures were measured or simulated for each room in both houses
244 throughout Summer and Winter. Here, we predominantly focus on those in
245 the southern bedroom both for brevity and as it was the room with the largest
246 RE or RE/iRE envelope (by metre of wall). Measured and simulated dry bulb
247 temperature in the southern bedroom and outdoors during Summer are shown
248 in Figures 2 to 4. The same results for Winter are shown in Figures 5 to 7.

Figure 1: Boxplots of measured and simulated outdoor hourly temperature in Summer and Winter

249 4.3.1. Summer

250 Figure 2 shows that internal temperature variation was significantly less than
251 that outside for both houses in Summer. Internal temperature variation was
252 broader for a given hour in the monolithic house than in the insulated (Fig-
253 ure 3). The insulated house had marginally higher temperatures overall, most
254 significantly from 21:00–09:00.

255 *BERS Pro* simulated internal temperatures were lower than measured as a
256 consequence of lower outdoor temperatures predicted for the period (Figure 1).
257 Temperature ranges per hour were similar throughout the day in both houses.
258 However, daily temperature variation was larger than for measured values, as were
259 hourly variations (likely due to the houses’ poorer simulated thermal stability,
260 covered in Part A of this series). Opposite to measured behaviour, simulated
261 variations were the largest from 10:00–21:00.

262 (Insert Figure 2 somewhere near here)

263 (Insert Figure 3 somewhere near here)

264 (Insert Figure 4 somewhere near here)

265 4.3.2. Winter

266 As for Summer, Figure 5 shows that internal temperature variations were sig-
267 nificantly less than those outdoors in Winter for both houses. However, surveys
268 revealed that occupants used portable heaters on various occasions, demonstrated
269 by sharp temperature spikes in Figure 5. Such spikes did not represent mean air
270 temperature. Rather, heaters were (unintentionally) positioned below ceiling sen-
271 sors in some rooms, generating false readings. Severe spikes were removed during
272 data cleaning. Remaining spikes were included in comfort assessments as their
273 presence was useful to indicate heating episodes. Again, internal temperatures

Figure 2: Head-level southern bedroom (BS) indoor and outdoor dry bulb temperatures during Summer, compared to *Chenath* and SET* comfort limits

Figure 3: Measured (“best”) Summer monolithic and insulated house hourly temperatures in the southern bedroom. Box necks show the 95% confidence interval on the mean (roughly 90 samples per analysed hour). + symbols are outliers

Figure 4: *BersPRO* simulated Summer monolithic and insulated house hourly temperatures in the southern bedroom. Format as per Figure 3

274 were warmer in the insulated house and temperature ranges per hour were smaller
275 (Figure 6). However, all temperature outliers (the majority positive) occurred for
276 the insulated house, indicating greater random variation (i.e. irregular heating).

277 Simulated results in Figure 7 demonstrate *BERS Pro*'s assumption of near-
278 constant heating in Winter: hourly ranges were significantly narrower than mea-
279 sured values due to tight heating control. Temperatures were also warmer than
280 measured values. Positive outliers occurred in both houses at every hour, corre-
281 sponding to heating episodes enforced by the comfort criteria: this is discussed in
282 more detail in the following sections. As a consequence of heating, temperatures
283 in both houses were highly similar. However, simulated temperature ranges in
284 the insulated house were somewhat broader and warmer from 10:00–16:00. These
285 hours were centred about the diurnal maximum (around 13:00–14:00) and corre-
286 sponded to warmer Winter days during the overall period when heating was not
287 applied. Part A demonstrated that the insulated house's thermal stability was
288 marginally worse than the monolithic's, hence its more notable reaction to higher
289 outdoor temperatures.

290 (Insert Figure 5 somewhere near here)

291 (Insert Figure 6 somewhere near here)

292 (Insert Figure 7 somewhere near here)

293 4.4. Thermal comfort

294 Thermal comfort scores for both houses using the *Chenath* and SET* methods
295 in Summer and Winter are given in Tables 5 and 6. “Best”, “high” and “low”
296 comfort calculations assumed airspeeds of 0.2m/s (minimum value in Eqn 2). An
297 additional “best” calculation was completed at 0.3m/s to examine the effect of
298 higher airspeeds on overall scores.

Figure 5: Head-level southern bedroom (BS) indoor and outdoor dry bulb temperatures during Winter, compared to *Chenath* and SET* comfort limits. Shaded regions denote times when houses were reported unoccupied

Figure 6: Measured Winter (“best”) monolithic and insulated house hourly temperatures in the southern bedroom. Format as per Figure 3

Figure 7: *BersPRO* simulated Winter monolithic and insulated house hourly temperatures in the southern bedroom. Format as per Figure 3

Table 5: *Chenath* method thermal comfort scores. “Best”, “High” and “Low” are results for different estimation methods. Bold entries show highest scores per analysis. ^a: calculated for airspeed of 0.2m/s. ^b: airspeed of 0.3m/s

Season	Room	Best		Best 0.3m/s		High		Low		Simulated	
		RE	iRE	RE	iRE	RE	iRE	RE	iRE	RE	iRE
Summer	Liv	88	89	96	95	85	84	97	97	84	83
	<i>BE</i>	93	89	98	97	91	87	97	97	92	94
	<i>BS</i>	94	90	98	97	92	88	98	97	94	94
	<i>BW</i>	88	87	96	95	86	84	97	97	92	92
	Kit	89	89	96	95	86	85	98	96	91	91
	Average	90	89	97	96	88	85	97	97	91	91
Winter	Liv	44	40	44	40	46	42	40	37	96	96
	<i>BE</i>	79	65	79	65	80	67	74	62	95	97
	<i>BS</i>	77	64	77	64	79	66	74	61	96	97
	<i>BW</i>	84	67	84	67	86	68	77	62	96	97
	Kit	43	41	43	41	45	42	39	38	97	97
	Average	65	55	65	55	67	57	61	52	96	97

299 (Insert Table 5 somewhere near here)

300 (Insert Table 6 somewhere near here)

301 4.4.1. Summer

302 Measured behaviour

303 *Chenath* comfort scores were over 80% in all rooms. Scores in the monolithic
304 house were marginally higher than in the insulated for all analyses. At no time did
305 hourly indoor temperatures fall below the heating threshold. Hence, “low” and
306 “high” estimates produced the highest and lowest scores due to the assumption
307 of lower or higher temperatures respectively.

308 *Chenath* and SET* TOC results for the southern bedroom (“best” estima-
309 tion) are shown in Figure 8. Note that Figure 8 shows the percentage time a
310 given hour was uncomfortable for that hour: the total detriment to the comfort
311 score (i.e. 100-score) is the average of the hourly values. Similar analyses were

Table 6: SET* method thermal comfort scores. Legend as for Table 5

Season	Room	Best		Best 0.3m/s		High		Low		Simulated	
		RE	iRE	RE	iRE	RE	iRE	RE	iRE	RE	iRE
Summer	Liv	94	99	91	98	94	99	89	97	63	63
	<i>BE</i>	94	98	89	98	94	98	90	97	65	66
	<i>BS</i>	93	98	87	97	94	98	89	96	60	61
	<i>BW</i>	95	98	91	98	95	98	90	98	66	67
	Kit	93	99	90	98	94	98	87	98	61	61
	Average	94	98	89	98	94	98	89	97	63	64
Winter	Liv	15	6	10	5	19	7	9	4	51	52
	<i>BE</i>	10	6	7	4	12	6	8	4	8	10
	<i>BS</i>	10	5	7	4	10	6	7	4	4	4
	<i>BW</i>	14	6	8	5	15	7	9	4	8	11
	Kit	14	6	9	5	17	7	7	4	54	54
	Average	13	6	8	4	15	7	8	4	25	26

312 completed for remaining rooms. By the *Chenath* method, 00:00–07:00 was the
 313 least comfortable period in all rooms in the insulated house. TOC was higher
 314 during that interval due to the lower value of T_n for sleeping periods in Eqn 1.
 315 This was also the least comfortable period in the monolithic house’s southern
 316 and eastern bedrooms. Given that living rooms and kitchens were likely to be un-
 317 occupied from 00:00–07:00, specifying “comfort” at these times was misleading;
 318 removing restrictions on T_n when sleeping, as for heating in living rooms, would
 319 more accurately reflect their use and improve scores. Notably, TOC results in
 320 the monolithic house’s western bedroom, living room and kitchen between 15:00–
 321 23:00 were as high as those for 00:00–07:00. Part A showed that these rooms had
 322 poorer thermal stability than the eastern and southern bedrooms due to their
 323 orientation and lower thermal mass envelopes respectively. These rooms also ex-
 324perienced thermal lags of roughly 1 hour. As such, temperatures in these rooms
 325 were higher in the afternoon and evening than in the other bedrooms, exceeding
 326 the *Chenath* waking cooling threshold. However, increasing “best” airspeed im-

proved comfort scores significantly: an airspeed of 0.3m/s produced similar comfort levels to the “low” estimate due to more-positive values of ΔT in Eqn 1. All rooms achieved 100% comfort at 0.6m/s, which could, for example, be provided by a pedestal or ceiling fan. Use of air movement also benefitted from low daily humidities (around 50%); if humidity was higher then higher airspeeds, perhaps outside the fans’ range, would have been needed. *Chenath* scores of 100% could therefore realistically be achieved in all rooms, agreeing with occupant feedback.

SET* Summer comfort scores were higher than *Chenath* scores: over 90% in both houses. Contrary to *Chenath*, SET* scores were higher in the insulated house by 4–9%: indeed, scores were close to 100% in the insulated house. This difference was due to marginally higher temperatures in the insulated house, as previously discussed: the majority of uncomfortable hours in both houses were *too cold* according to the SET* comfort thresholds. Hence, the “low” estimation method received the lowest score. Similarly, increasing airspeed was detrimental. For the few hours that fell below comfort, 06:00–07:00 was the least comfortable time in all rooms in the monolithic house, corresponding to daily diurnal minima. Discomfort was also high around 16.00 in the living areas, corresponding to those days with high external maximum temperatures (close to 40°C) combined with the room’s thermal lag, as discussed above. All TOC values were similar in the insulated house according to the SET* thresholds.

Overall, both the *Chenath* and SET* gave high comfort scores in Summer, agreeing with occupant feedback. However, as occupants did not report any instances of being too cold, the SET* method was less appropriate despite achieving higher comfort scores in some cases. Specifying separate waking and sleeping comfort criteria in *Chenath* was therefore beneficial for describing Summer performance.

Figure 8: *Chenath* and SET* measured ("best" estimate) percentage TOC per hour for summer in the southern bedrooms

353 (Insert Figure 8 somewhere near here)

354 *Simulated behaviour*

355 *BERS Pro* hourly humidity values were not available. Therefore, humidity
356 was set to 50% in Eqn 2, removing its contribution to ΔT . 50% was representative
357 of 30-year annual average humidity in Kalgoorlie-Boulder (Australian Bureau of
358 Meteorology). An indoor airspeed of 0.2m/s was also assumed.

359 *Chenath* comfort scores were >80% for all rooms in both houses in Summer,
360 similar to measured “best” scores. No hourly temperatures fell below the heating
361 threshold. However, it is unclear from temperature values alone whether this was
362 due to the houses’ passive performance or infrequent instances of artificial heating,
363 allowed under the *BERS Pro* comfort hierarchies. Most hours fell within the
364 comfort boundaries: discomfort did not vary significantly between hours for those
365 that did not. Based on measured data, including humidity effects in Eqn 2 would
366 increase the cooling threshold by 1–2°C, almost eliminating discomfort. Without
367 accounting for air humidity, increasing airspeed to 0.6m/s also achieved 100%
368 comfort for all rooms. *Chenath* comfort scores for both houses were therefore
369 notionally 100%: as *BERS Pro* is built on *Chenath*, such a result was expected.

370 Both houses received similar SET* scores for *BERS Pro* data. However, scores
371 up to 30% lower than those for measured values. Unlike *Chenath*, no temperatures
372 exceeded the SET* cooling threshold but intermittently fell below the heating
373 threshold, accounting for the lower scores. Peak discomfort occurred between
374 06:00–07:00 in all rooms (e.g. Figure 9 for the southern bedroom), corresponding
375 to outdoor temperature diurnal minima. As uncomfortable hours were deemed
376 too cold, including humidity effects or increasing airspeed *lowered* comfort scores.
377 Given the (sometimes) extreme outdoor temperatures, such a result was unreal-

378 istic: as found for measured behaviour, the SET* method's poorer performance
379 was due to its high Summer heating threshold.

380 (Insert Figure 9 somewhere near here)

381 4.4.2. Winter

382 *Measured behaviour*

383 Sleeping and living areas scored differently in Winter under *Chenath* as the
384 method applies different heating comfort criteria to each. Overall Winter *Chen-*
385 *ath* scores were higher in the monolithic house by roughly 10%. The greatest
386 differences were between the bedrooms: monolithic scores were around 80% but
387 insulated scores around 60%. Such a result may be unexpected, given the higher
388 mean hourly temperatures in the insulated house's bedrooms (e.g. Figure 6).
389 However, no hourly temperatures exceeded the cooling threshold. Hence, higher
390 upper quartile temperatures in the monolithic house *during sleeping periods* pro-
391 duced higher scores. Figure 10 shows that the least comfortable hours in the
392 bedrooms were 08:00 and 18:00–00:00 for both houses. *Chenath* assumes that
393 bedrooms were unoccupied from 09:00 to 16:00, hence no uncomfortable hours
394 occurred during this period. The jump in discomfort at 08:00 was due to the
395 transition to a higher 07:00–08:00 heating threshold. Such a sudden shift in
396 perceived comfort is unlikely: removing it by extending the 00:00–07:00 heating
397 threshold to 08:00 marginally improved overall bedroom comfort scores by 1.5%
398 in the insulated house and 3% in the monolithic house. Discomfort prior to 08:00
399 was lower due to the lower sleeping period heating threshold.

400 (Insert Figure 10 somewhere near here)

401 *Chenath* Winter scores in the living rooms and kitchens were low in both

Figure 9: *BERS Pro Chenath* and SET* percentage TOC per hour in summer in the southern bedroom

Figure 10: Southern bedroom measured TOC (*Chenath* and SET* methods, “best” estimate) in Winter

402 houses: roughly 40%. Again, no hourly temperatures exceeded the cooling thresh-
403 old. Hourly TOC in the living rooms is shown in Figure 11: distributions were
404 different to those in the bedrooms, due to the different heating threshold require-
405 ments. Living rooms and kitchens were assumed to be unoccupied from 00:00
406 to 07:00: TOC was zero during those times. A single heating threshold of 20°C
407 was applied at 08:00. In the insulated house, all hours 08:00–00:00 were simi-
408 larly uncomfortable: occupants did not heat the living room up to the assumed
409 *Chenath* heating threshold. Discomfort marginally dropped in the monolithic
410 house around 14:00, corresponding to outdoor temperature diurnal maxima; as
411 discussed in Part A, the monolithic house, sited to the East of the insulated,
412 marginally benefitted from less shading.

413 (Insert Figure 11 somewhere near here)

414 (Insert Table 7 somewhere near here)

415 SET* Winter comfort scores were poor in both houses: <15% in the mono-
416 lithic house and <10% in the insulated. No temperatures in the monolithic house
417 exceeded the cooling threshold. Isolated incidents of temperatures exceeding the
418 cooling threshold occurred in the insulated house due to heating spikes. “Low”
419 estimates and increased airspeeds increased the heating and cooling thresholds
420 and so reduced comfort scores. Hourly TOC was similar throughout the day in
421 all rooms in both houses, shown in Figures 10 and 11. Again, an exception was
422 around 14:00 in the monolithic house’s living room, where discomfort marginally
423 reduced due to outdoor diurnal maxima. As for Summer, poor scores stemmed
424 from a heating threshold that was much higher than that adopted by the occu-
425 pants.

426 Overall, the *Chenath* method was able to approximate occupant feedback but
427 imposed heating thresholds were too high, leading to lower scores. As for Summer,

Figure 11: Living room measured TOC (*Chenath* and SET* methods, “best” estimate) in Winter

specifying different criteria for sleeping and waking times was advantageous, but using rigidly-defined values and heating times was detrimental. This was reflected in scores from the SET* method, whose high heating threshold made it entirely inappropriate for judging Winter comfort, given that occupants did not report any uncomfortable times. To highlight the effect of high heating thresholds on comfort scores, scores corresponding heating thresholds reduced by only 2°C are given in Table 7: *Chenath* kitchen and living room scores improved by 32% in the monolithic house and by 16% in the insulated house, almost matching bedroom scores in both cases, and all SET* scores improved by up to 40%.

Simulated behaviour

All rooms required heating in Winter when simulated using *BERS Pro*, as shown previously in Figure 5. Two separate heating events occurred per day in the bedrooms, coinciding with the start of the two comfort-specified periods (00:00–08:00 and 17:00–23:00). One heating event occurred in the living rooms, starting at 08:00.

Chenath comfort scores were >95% in all rooms. Rapid changes in comfort criteria led to some instances of temperatures falling below the heating threshold. In the bedroom, sudden TOC peaks occurred at 08:00 and 17:00 (Figure 12). Similarly, a single peak occurred at 08:00 in the living room (Figure 13). Such peaks did not reflect expected occupant comfort; rather, they reflected discontinuities in *Chenath*'s heating thresholds. Providing a more continuous heating threshold definition would likely remove these instances. Rarely, indoor hourly temperatures exceeded the heating threshold. Such instances occurred when outdoor peak temperatures exceeded 25°C. On these days, heating was not required and the house ran freely.

Table 7: Effect of reducing heating thresholds by 2°C on *measured* data *Chenath* and SET* Winter comfort scores. Unaffected rooms shown in *italics*. RT: Reduced Threshold. Other labels as for Table 5

House	Room	<i>Chenath</i>			SET*		
		Original (%)	RT (%)	Change (%)	Original (%)	RT (%)	Change (%)
Insulated	Liv	40	55	16	6	25	19
	<i>BE</i>	<i>65</i>	<i>65</i>	<i>0</i>	6	24	19
	<i>BS</i>	<i>64</i>	<i>64</i>	<i>0</i>	5	23	18
	<i>BW</i>	<i>67</i>	<i>67</i>	<i>0</i>	6	28	21
	Kit	41	56	16	6	25	19
	Average	55	62	6	6	25	19
Monoithic	Liv	44	76	32	15	58	43
	<i>BE</i>	<i>79</i>	<i>79</i>	<i>0</i>	10	49	38
	<i>BS</i>	<i>77</i>	<i>77</i>	<i>0</i>	10	46	36
	<i>BW</i>	<i>84</i>	<i>84</i>	<i>0</i>	14	56	42
	Kit	43	74	31	14	55	41
	Average	65	78	13	13	53	40

453 SET* comfort scores exceeded 50% in the living rooms and kitchens but
 454 largely fell below 10% in the bedrooms. In the bedrooms, almost all hours fell
 455 below the heating threshold; neither *BERS Pro* heating episode was sufficient to
 456 elevate temperatures above the SET* heating threshold. In the living rooms and
 457 kitchens, a single heating episode was sufficient to elevate temperatures above
 458 the SET* heating threshold. However, as discussed in Part A of this series, these
 459 rooms' thermal stabilities were poorly captured by *BERS Pro*. Consequently,
 460 temperature rose rapidly at the onset of heating and fell rapidly at its termi-
 461 nation, so that hourly TOC fell dramatically around 14:00, corresponding to
 462 the combined maximum heating effect and outdoor diurnal maxima. Such rapid
 463 changes were not representative of those rooms in reality.

464 (Insert Figure 12 somewhere near here)

465 (Insert Figure 13 somewhere near here)

Figure 12: Southern bedroom *BERS Pro* TOC (*Chenath* and SET* methods, “best” estimate) in Winter

Figure 13: Living room *BERS Pro* TOC (*Chenath* and SET* methods) in Winter

4.5. Comfort model consequences on energy efficiency

heating takes a lot of energy due to high thermal mass (density and specific heat cap)

Several differences between measured and simulated performance were apparent. The most critical was *BERS Pro*'s requirement for near-constant heating in Winter. Heating was needed in reality, however rooms were not heated up to the *Chenath* (or SET*) thresholds. Given RE and iRE's high thermal mass (high density and specific heat capacity), additional heating represents a large energy demand. Winter heating demands should therefore have been significantly lower than predicted. Simulations also assumed that artificial cooling was required in the living rooms and kitchens in Summer. In reality, this was not the case as these rooms were significantly more thermally stable (discussed in Part A of this series). Summer cooling energy demands should therefore have been lower (if not zero) for both houses. A consequent quantitative reduction in simulated energy demand cannot be determined; however, the discussion provided above demonstrates that the houses' energy efficiency, predominantly in Winter, was considerably higher than those predicted by *BERS Pro*.

5. Conclusions

This series examined the performance of two RE houses in Kalgoorlie-Boulder, Western Australia. The houses were built to optimise passive solar properties and comprised mixes of RE, iRE and lightweight insulated walls. A substantial sensor and logging array was installed in each house to monitor unoccupied and occupied performance. Performance was also simulated using the state-of-the-art thermal modelling software *BERS Pro* v4.3 and assessed qualitatively through monthly

490 occupant surveys. Indoor and outdoor data was gathered over the course of two
491 years and the cleaned data used in this series has been made freely available for
492 future research. This paper investigated the houses' thermal performance when
493 occupied during Summer and Winter.

494 The houses' performance in Winter was poorly reflected by the *Chenath* and
495 SET* method comfort criteria. Occupants reported that both houses were com-
496 fortable in Summer and largely comfortable in Winter, although infrequent heat-
497 ing was required. In Summer, *Chenath* and SET* comfort scores largely agreed
498 with occupant perceptions. *BERS Pro* simulations were also similar to measured
499 performance in Summer. However, Winter scores for measured data were poor
500 and did not reflect occupant feedback. Simulations also demanded artificial heat-
501 ing in all rooms throughout Winter. Contrasting the *Chenath* and SET* methods
502 and hourly TOC demonstrated that poor Winter performance was due to high
503 heating thresholds. The effect of reducing heating threshold demands by 2°C,
504 in agreement with occupant behaviour, on perceived comfort was demonstrated:
505 comfort scores improved by up to 40% in some cases. Given that heating consti-
506 tutes the greatest energy demand for these houses, *BERS Pro* simulated energy
507 demands were likely far higher than in reality. However, results presented here
508 are for a case study only: as a subjective quantity, we cannot claim that occupant
509 comfort judged here reflects that of all occupants in low-energy homes in this or
510 other climates.

511 **Acknowledgements**

512 The authors would like to thank Mr Adrian Welke of Troppo Architects for his
513 input throughout the project. We would also like to thank Mr Barron Bonney of
514 the Indigo Mining Services for his help with running initial experiments, on-site

515 technical support and for running occupant surveys. Funding for this project was
516 from the Australian Research Council (ARC), the Western Australia Department
517 of Housing Go8-DAAD. Work presented here was conducted under ARC Linkage
518 Grant LP140100375 and UWiN - Underground Wireless Sensor Networks. This
519 research was approved by the Human Research Ethics Office of the University of
520 Western Australia (RA/4/1/7273).

References

- [1] ANSI/ASHRAE, 2010. ASHRAE Comfort Standard 55-2010: Thermal environmental conditions for human occupancy.
- [2] Cardell-Oliver, R., Sarkar, C., 2016. Robust sensor data collection over a long period using virtual sensing. In: TSAA 2016: Workshop on Time Series Analytics and Applications. pp. 1–6.
- [3] Chen, D., 2016. AccuRate and the Chenath engine for residential house energy rating. [accessed: 25/01/2017].
URL <https://hstar.com.au/Home/Chenath>
- [4] Ciancio, D., Beckett, C. T. S. (Eds.), 10–13 February 2015. Rammed earth construction: Cutting edge research on traditional and modern rammed earth. International Conference on Rammed Earth Construction. University of Western Australia, CRC Press (The Netherlands), Perth, WA.
- [5] Ciancio, D., Jaquin, P., Walker, P., 2013. Advances on the assessment of soil suitability for rammed earth. *Construction and Building Materials* 42, 40–47.
- [6] Daniel, L., Soebarto, V., Williamson, T., 2012. Evaluating the suitability of the AccuRate engine for simulation of massive construction elements. In: Proceedings of the 46th Annual Conference of the Architectural Science Association (ANZAScA). Griffith University, Queensland (Australia).
- [7] Daniel, L., Soebarto, V., Williamson, T., 25–28 August 2013. Assessing the simulation capability of the AccuRate engine in modelling massive construction elements. In: Proceedings of the 13th International Conference of the International Building Performance Simulation Association. International Building Performance Simulation Association, Chambéry, France.
- [8] Daniel, L., Soebarto, V., Williamson, T., 2015. House energy rating schemes and low energy dwellings: The impact of occupant behaviours in australia. *Energy and Buildings* 88, 34–44.
- [9] Daniel, L., Williamson, T., Soebarto, V., Chen, D., 10–13 April 2014. A study of thermal mavericks in Australia. In: Proceedings of the Eighth Windsor Conference: Counting the cost of comfort in a changing world. Network for Comfort and Energy Use in Buildings, London, Cumberland Lodge, Windsor, UK, pp. 1–16.
- [10] de Dear, R., Brager, G. S., 1998. Developing an adaptive model of thermal comfort and

- 552 preference. ASHRAE Transactions 104, 145–167.
- 553 [11] Delsante, A., 2005. Is the new generation of building energy rating software up to the task?
- 554 — a review of *AccuRate*. In: Building Australias Future 2005. ABCB, pp. 1–15.
- 555 [12] Isaacs, T., May 2005. Accurate: 2nd generation nationwide house energy rating software.
- 556 Environment Design Guide DES 23, BDP.
- 557 [13] Jaquin, P. A., Augarde, C. E., Gerrard, C. M., 2008. A chronological description of the
- 558 spatial development of rammed earth techniques. International Journal of Architectural
- 559 Heritage: Conservation, Analysis and Restoration 2 (4), 377–400.
- 560 [14] Miller, W., Buys, L., Bell, J., 2012. Performance evaluation of eight contemporary passive
- 561 solar homes in subtropical australia. Building and Environment 56, 57–68.
- 562 [15] Saman, W., Oliphant, M., Mudge, L., Halawa, E., 2008. Study of the effect of temperature
- 563 settings on AccuRate cooling energy requirements and comparison with monitored data.